

Mold spore counts in the home “before” and “after” the crawl space restoration.

Type of Mold	Spores/m ³					
	Crawl space		First Floor		Second floor	
	Before	After	Before	After	Before	After
Asp/Pen	1,200	0	3,100	0	0	0
Other	600	300	800	100	200	70
Total Spores	1,800	300	3,900	100	200	70